

Ref.: Date: الرقم: مياھنا ٨٤٢ | ٤٤ التاريخ: ١٦/١٥/٢٠٢٢

السادة :  
فاكس :  
هاتف :

الموضوع : الملحق رقم (1) للمناقصة رقم O-P-22-056-B

تحية طيبة وبعد،

بخصوص المناقصة أعلاه والمتعلقة ب توريد قطع غيار مضخات ، وبناء على الاستفسارات المقدمة من احد الموردين ، حيث تمت الاجابة كما يلي:

- The pump 18.5 kw , please provide further details of the pump material/type/application or alternately ?

• الاجابة حسب المرفق

وعليه فقد تقرر تمديد مدة البيع لغاية 2022/06/22 وموعد استلام وفتح العروض يوم الاحد الموافق 2022/06/26 لغاية الساعة الحادية عشر بدلاً من يوم الاحد الموافق 2022/06/19.

مع اعتبار هذه الملحق جزء لا يتجزأ من وثائق المناقصة مع البقاء على كافة التفاصيل كما هي

مع الإحترام والتقدير

مدير مديرية العطاءات والمشتريات

احمد اللوزي

نوف الصنابحي  
مدير

- مرفقات عدد (1)

Ref.:

Date:

التاريخ :

الرقم :

Please kindly note that the materials from which the pump is made are as follows :

Hydraulic	
Suction nozzle	200mm drilled to PN 10
Discharge nozzle	200 mm drilled to PN 10
Type:	EQ8Q
Impeller	SL
Free passage	100 mm
Inspection cover	Yes
Material of Hydraulic	
volute casing	0.6025(GG25)
Impeller	0.7060(GGG60)
Liner:	0.6020(GG20)
Seal parts	0.6020(GG20)
Shaft:	1.4021(X20Cr13)
Seal motor side:	G.Type-SiC
Seal motor side	M.Type-SiC/WC
O-Rings	Nitrile
Instrumentation	
Moisture probe	Yes
Float switch	no
Bearing TEMP Probe	No
Temperature probe	No
Miscellaneous	-
Painting	Standard painting
Paint Thickness	300µm special